



Notified Body No 1023
INSTITUTE FOR TESTING AND CERTIFICATION, Plc
Trida Tomase Bati 299, Louky, 763 02 Zlin, CZECH REPUBLIC

CERTIFICATE OF CONSTANCY OF PERFORMANCE No 1023-CPR-0718 P

Construction product: **Thermal insulation boards of mineral wool TECHNOFACADE COTTAGE** (thicknesses: 50-200 mm, density:95-115 kg/m³), **TECHNOFACADE OPTIMA** (thicknesses: 50-200 mm, density:110-130 kg/m³), **TECHNOFACADE EXTRA** (thicknesses: 50-200 mm, density:80-100 kg/m³)

Product parameters: **TECHNOFACADE COTTAGE: T4- DS(70,-)- DS(23,90)-CS(10)30- TR10- PL(5)150-WS-WL(P)-MU1, R_{tF}:A1, λ_D= 0.036 W/(m.K)**
TECHNOFACADE OPTIMA: T4- DS(70,-)- DS(23,90)-CS(10)30- TR15- PL(5)200-WS-WL(P)-MU1, R_{tF}:A1, λ_D= 0.037 W/(m.K)
TECHNOFACADE EXTRA: T4- DS(70,-)- DS(23,90)-CS(10)15- TR5- PL(5)50-WS-WL(P)-MU1, R_{tF}:A1, λ_D= 0.036 W/(m.K)

Intended products use: **Thermal insulation for buildings**

Placed on the market under the name or trade mark of: **«Zavod Techno» LLC**
Ryazan, Vostochny promuzel 21,
b. 58, 390000 Russian Federation

Relevant standard(s): **EN 13162:2012+A1:2015** Thermal insulation products for buildings – Factory made mineral wool (MW) products – Specification

Final Report No: **753501211 / 2015**

Certificate first issued on: 2015-12-31

Notified Body No 1023, in compliance with Regulation (EU) No 305/2011 (CPR), attests that:

- All provisions relating to the Assessment and Verification of Constancy of Performance (AVCP) described in Annex ZA of the above harmonized standard(s) under **AVCP System 1 (1+3)** have been applied
- The performance of the construction product above has been assessed to remain constant.


The assessment of performance of the construction product and findings from the initial inspection of the manufacturing plant and factory production control are summarized in the above mentioned Final Report.

This certificate remains valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the Notified Body.

CE

Date of issue:

2015-12-31



Dr Radomir CEVELIK
Representative of Notified Body No 1023